



DİDİM ATIK SU ARITMA TESİSİ

Date 29.01.2021
Ed RAMAZ
Appr

ADP PANOSU
BESLEME

Q1
1600A
AYARLI TMS

ENERJİ
ANALİZÖR

1600/5

400A
AYARLI TMS

NYN

7 m
3x(1x150)+95
300/500V

160KW SÜRÜCÜ
BESLEME

400A
AYARLI TMS

NYN

6 m
3x(1x150)+95
300/500V

160KW SÜRÜCÜ
BESLEME

400A
AYARLI TMS

NYN

5 m
3x(1x150)+95
300/500V

160KW SÜRÜCÜ
BESLEME

400A
AYARLI TMS

NYN

4 m
3x(1x150)+95
300/500V

160KW SÜRÜCÜ
BESLEME

Modification	Date	Name	Appr	Original
	29.01.2021	RAMAZ		

Replacement of

Barlıcazı Nr

7 NOLU ATIK SU TERFİ MERKEZİ MCC
GÜÇ PANOSU

400VAC
ŞEBEKE BESLEME

NYN
10 m
3x50+25
300/500V

Q1
160A

ENERJİ
ANALİZÖR

160/5

F1
50A

FC1

22KW

POMPA-1

M1

22KW

POMPA

F2
50A

FC2

22KW

POMPA-2

M2

22KW

POMPA

F3
50A

FC3

22KW

POMPA-3

M3

22KW

POMPA

25A

PLC PANOSU

1/1,6

KESİNTİSİZ
GÜÇ KAYNAĞI

HMI PANEL
PLC

SEVİYE SENSÖR

FLATÖR

FLATÖR

FLATÖR

FLATÖR

Modification	Date	Name	Appr	Original
	29.01.2021	RAMAZ		

Declaration of

Drawn and

NAZILLI ATIK SU ARITMA TESİSİ

